



# AC156 Seismic Qualification Testing of Stored Energy Systems LLC SuperTorque 8Z Engine Starters

Qualification Level:  
S<sub>DS</sub> = 2.0g, z/h = 1.0  
S<sub>DS</sub> = 2.5g, z/h = 0.0

Report Prepared For: **Stored Energy Systems LLC**

Testing Conducted at:  
Dynamic Certification Laboratories  
1315 Greg Parkway Suite 109  
Sparks, NV 89431

Shake Table Test Date(s): 8/4/2022  
Report Date: 9/6/2022  
Revision Date: 9/14/2022

Tested Equipment Manufactured and Provided by: **Stored Energy Systems LLC**

Prepared By:

*Daniel Rodgers*

**Daniel Rodgers,  
Seismic Test Engineer**

9/14/2022

**Date**

Reviewed for Compliance  
AC156 and CBC 2019



*Ken H. Tarlow*

Date:09/15/2022

Reviewed By:

*K. Laplace*

**Kelly Laplace,  
Business Manager**

9/14/2022

**Date**



This test report shall not be reproduced except in full, without the written approval of the laboratory. The results herein relate only to the items received and tested for Project No. 10420-2201.

Report # DCL-10420-2201-REV01-AC156  
DCL Doc. R.1, Rev 4